



Number	18GR0357/01	Replaces	18GR0357/00
Issue date	29-11-2021	Contract number	E8690
Due date	29-11-2031	Module	B (Type testing)
Report number	177155	Scope	(EU) 2016/426 (9 March 2016)
PIN	0063BQ3155	Page	1 of 1

APPENDIX TO EU TYPE EXAMINATION CERTIFICATE (GAR)

Manufacturer:

HAJDU Hajdúsági Ipari Zrt.

Types:

HGK 24, HGK 28, HGK 36

Appliance types:

B₂₃, B₃₃, C_{13(X)}, C_{33(X)}, C_{43(X)}, C_{53(X)}, C_{63(X)}, C_{83(X)}, C_{93(X)}

Appliance categories:

II_{2H3P}

Gas groups and supply pressures:

H: 20 mbar; 25 mbar; P: 30 mbar; 37 mbar; 50 mbar;

Countries:

Hungary

Flue systems:

Almeva Double (LIK)

Concentric air-flue gas system in diameters 60/100 mm and 80/125 mm.

Inner/Outer duct: PPH/PPH

Approved flue terminals:

- 60/100 mm, wall terminal, LPALK5
- 80/125 mm, wall terminal, LPALK8
- 60/100 mm, roof terminal, DPDS45_(DPDT45)
- 80/125 mm, roof terminal, DPDS48_(DPDT48)

Designation: T120 – H1 – O – W – 2 – O00 – LI – E – U1

Remarks:

--



Number	18GR0357/01	Replaces	18GR0357/00
Issue date	29-11-2021	Contract number	E8690
Due date	29-11-2031	Module	B (Type testing)
Report number	177155	Scope	(EU) 2016/426 (9 March 2016)
PIN	0063BQ3155		

EU TYPE EXAMINATION CERTIFICATE (GAR)

Kiwa hereby declares that the condensing boilers, type(s):

**HGK 24,
HGK 28,
HGK 36**

Manufacturer

**HAJDU Hajdúsági Ipari Zrt.
Téglás, Hungary**

meet(s) the essential requirements as described in the
Regulation (EU) 2016/426 relating to appliances burning gaseous fuels.

Reference standard: EN 15502-1:2012+A1:2015 and EN 15502-2-1:2012+A1:2016

This certificate is only valid in combination with the appendix to this certificate, where specific information and/or conditions are given.

CERTIFICATE